

From: Robert Siegfried [<mailto:rsiegfried@valleywater.org>]
Sent: Friday, February 18, 2011 10:41 AM
To: Agriculture Water Use Efficiency
Subject: Comment on reporting of measurement accuracy

AgWUE,

Many, perhaps most, districts measure with a number of different types of measurement devices according to site specific requirements. Stratification of sampling should be required to capture and represent the variation in accuracy inherent to each type of device. Reporting of a district's overall measurement accuracy should be an average derived from weighted averages for each type of device. Weighting should reflect the proportions of occurrence of the various devices within the district.

Bob Siegfried
Santa Clara Valley Water District
5750 Almaden Expressway
San Jose CA 95118
408 265 2607